



DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

July 19, 2013

ACORN ENGINEERING COMPANY
FARHAD SHAHRIARY
15125 PROCTOR AVE
CITY OF INDUSTRY CA 91746

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: ACORN ENGINEERING COMPANY
Product Name: SWIVETTE (CAREWARE)
Model Number(s): 4010, 4012, 4015, 4020, 4022, 4025, 4030, 4032 AND 4035
Product File No: 20130158

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2018.

This approval supersedes the approval issued on October 22, 2008 under product file number 20080484.

This approval is contingent upon compliance with the following stipulation(s):

- Installation of this product must include the optional anti-siphon pressure type vacuum breaker serving the bed pan washer. The anti-siphon pressure type vacuum breaker must be listed by a nationally recognized listing agency as conforming to ASSE Standard 1056. Specific plan approval from the department must be obtained for the installation of the anti-siphon pressure type vacuum breaker in health care and related facilities.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail